

Emergency Generators

NJAC 7:27-19.11

- (A) The Owner or operator of an emergency generator shall...maintain on site and record in a log book or a computer data system, the following:
1. Once per month, the total operating time from the generator hour meter;
 2. For each time the emergency generator is specifically operated for testing or maintenance:
 1. The reason for its operation;
 2. The date(s) of operation and the start up and shut down time;
 3. The total operating time for testing and maintenance based on the generator's hour meter; and
 4. The name of the operator; and
 3. If a voltage reduction is the reason for the use of the emergency generator, a copy of the notification of the voltage reduction from the PJM or other documentation of the voltage reduction.
- (B) The owner operator of the emergency generator shall maintain the records required under (A) above for a period of no less than five years after the record was made and shall make the records readily available to the Department or EPA upon request.